




# EU Declaration of Conformity

## 5580 Smart Vibration Signal Conditioner & SW5580 Dual Channel Configurable Switch

<b>Manufacturer's Name</b>	Metrix Instrument Co., L.P.
<b>Manufacturer's Address</b>	8824 Fallbrook Drive, Houston, TX 77064 USA 281.940.1802 <a href="http://www.metrixvibration.com">www.metrixvibration.com</a> <a href="mailto:info@metrixvibration.com">info@metrixvibration.com</a>
<b>Declares that the product</b>	Model 5580 Smart Vibration Signal Conditioner & SW5580 Dual Channel Configurable Switch (This declaration of conformity is issued under the sole responsibility of Metrix Instrument)
<b>Directive 2014/34/EU ATEX</b>	<b>Provision of the Directive fulfilled by the Equipment</b> <ul style="list-style-type: none"><li>•  II 3 G</li><li>• Ex ec nC IIC Gc</li><li>• 5580 model: Ta -40°C to +85°C</li><li>• SW5580 model: Ta -40°C to +65°C</li></ul>
<b>Conforms to the following standards</b>	<b>ATEX</b> <ul style="list-style-type: none"><li>• EN IEC 60079-0:2018</li><li>• EN 60079-7:2015+A1:2018</li><li>• EN 60079-15:2019</li></ul>
<b>EU-Type Examination</b>	<b>Certificate</b> <ul style="list-style-type: none"><li>• ITS-I21ATEX30380X</li><li>• Intertek Testing &amp; Certification Limited Cleeve Road Leatherhead Surrey, KT22 7SA, United Kingdom</li><li>• Notified Body Number: 0359</li></ul>
<b>Notified Body for production</b>	N/A for Zone 2 Type Certification
<b>Technical File Location</b>	The Technical File required by this Directive is maintained by the manufacturer listed above and the address listed above.
<b>Approved By</b>	  Lance Truong Quality Manager, Metrix Instrument Co. Houston, Texas 77064 November 17, 2021